

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7135-0067:178 Page 1 of 1

CATEGORY: Audible Devices

LISTEE: Siemens Building Technologies Inc., *Fire Safety Div., 8 Fernwood Rd, Florham Park NJ 07932
Contact: Peter Pawchak (973) 593-2662

DESIGN: Models MT-F, MT-C, MT-S, MTL-F, MTL-S, MTL-C electronic horns; Models MT-S15, MT-S17, MT-S75, MT-S110, EH-S15, EH-S17, EH-S75, EH-S110, MTL-S15, MTL-S17, MTL-S75 and MTL-S110, followed by suffix -F, -S or -C electronic horn/strobes. Models MTL-F, MTL-S, MTL-C, MTL-S15-F, -S, -C, MTL-S17-F, -S, -C, MTL-S75-F, -S, -C and MTL-S110-F, -S, -C are multi-tone audible devices. Refer to strobe's listing for type of strobe and listee's printed data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 12 VDC, 21-32 VDC
Candela: -S15 (15 cd), 60 flashes/min
-S17 (15/75 cd), 60 flashes/min
-S75 (75 cd), 60 flashes/min
-S-110 (110 cd), 60 flashes/min

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or Cerberus Pyrotronics, model number, electrical rating and UL label.

APPROVAL: Listed as multi-tone electronic horns or multi-tone horn/strobes for use with separately listed electrically compatible fire alarm control units. For indoor use only.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

XLF: 7135-0065:133

*Rev. 10-26-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **OCTOBER 26, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager